

Numero / Number KIP-050393/01 Sostituisce / Replaces 12/09/2008
26/11/2008
06/04/2009

Emesso / Issued 11/06/2009 Scopo / Scope Directive 90/396/EEC
Directive 92/42/EEC

Rapporto / Report 300988

NIP/ PIN 0694BR0988

**CERTIFICATO DI ESAME CE DI TIPO
EC TYPE EXAMINATION CERTIFICATE**

Kiwa Gastec dichiara che i prodotti
Kiwa Gastec hereby declares that the products

caldaie a condensazione
central heating condensing boilers

Marchio / trade mark: **IMMERGAS**

Modelli / models: VICTRIX X 12 2 I VICTRIX ZEUS 26 1 I
VICTRIX 26 2 I HERCULES SOLAR 26 1 A
VICTRIX X 24 2 I

costruite da / **Immergas S.p.A.**
made by Brescello (RE), Italia

soddisfano i requisiti riportati nella
meets the essential requirements as described in the

Direttiva Apparecchi a Gas (90/396/CEE) e Direttiva Rendimenti (92/42/CEE)
Directive on appliances burning gaseous fuels (90/396/EEC) and in the Directive on efficiency requirements (92/42/EEC)

I suddetti prodotti sono stati approvati per
Mentioned products have been approved for

Tipi di apparecchi / *appliance type* : B_{23P}, B₃₃, C₁₃, C₂₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃

I sopra menzionati apparecchi (ad eccezione del tipo C₆₃) sono forniti insieme ai sistemi fumari IMMERGAS appartenenti alla "Serie Verde"
The above mentioned appliances (except type C₆₃) are supplied together with the flue pipe systems IMMERGAS belonging to "Serie Verde"

Paesi e categorie apparecchi / *Countries and appliance categories*

AT	II _{2H3B/P}	BE	I _{2E(S)B} , I _{3P}	BG	II _{2H3B/P} , II _{2H3P}
CH	II _{2H3B/P}	CY	I _{3B/P} , I _{3B}	CZ	II _{2H3B/P}
DE	II _{2ELL3B/P}	DK	II _{2H3B/P}	EE	II _{2H3B/P} , II _{2H3P}
ES	II _{2H3P}	FI	II _{2H3B/P}	FR	II _{2Esi3P}
GB	II _{2H3P}	GR	II _{2H3B/P}	HU	II _{2HS3B/P}
IE	II _{2H3P}	IS	I _{3P}	IT	II _{2H3B/P}
LT	II _{2H3B/P} , II _{2H3P}	LU	II _{2E3P}	LV	I _{2H}
MT	I _{3B/P} , I _{3B}	NL	II _{2L3B/P}	NO	II _{2H3B/P}
PL	II _{2ELwLs3B/P}	PT	II _{2H3P}	RO	II _{2H3B/P}
SE	II _{2H3B/P}	SI	II _{2H3B/P} , II _{2H3P}	SK	II _{2H3B/P} , II _{2H3P}
TR	II _{2H3B/P}	AL	II _{2H3B/P} , II _{2H3P}	HR	II _{2H3B/P} , II _{2H3P}
MK	II _{2H3B/P} , II _{2H3P}				

Kiwa Italia S.p.a.


Sede Legale:
Via Angelo Maj, 12
20135 Milano

Sede Amministrativa e operativa:
Via Treviso, 32/34
31020 San Vendemiano (TV)


www.1kiwa.com

GASTEC

Kiwa Gastec



Ing. R. Karel
Director Product Certification



Certificato

Numero / Number KIP-050391/01 Sostituisce / Replaces --
KIP-050393/01
Emesso / Issued 11/06/2009 Scopo / Scope Directive 92/42/EEC
Rapporto / Report 300988
NIP/ PIN 0694BR0988

Annex 1 to certificate PIN 0694BR0988

Attribuzione delle marcature di rendimento energetico:
Award of Energy-Performance labels:

Marchio / trade mark: **IMMERGAS**

Modelli / models:

Livello stelle / Star level:

HERCULES SOLAR 200 CONDENSING
HERCULES SOLAR 26 1 A

☆☆☆☆*
☆☆☆☆*

* Rendimento al carico parziale per caldaie modulanti secondo la EN483/A2 e EN677
Efficiency partload for modulating boilers according to EN483/A2 and EN677.

Certificato

Kiwa Italia S.p.a.


Sede Legale:
Via Angelo Maj, 12
20135 Milano

Sede Amministrativa e operativa:
Via Treviso, 32/34
31020 San Vendemiano (TV)


www.kiwa.com

GASTEC

Kiwa Gastec



Ing. R. Karel
Director Product Certification





Kiwa Italia S.p.a.

Sede Legale:
Via Angelo Maj, 12 - 20135 Milano (MI)

Sede Amministrativa:
Via Treviso, 32/34 - 31020 San Vendemiano (TV)
Tel. +39 0438 411755 - Fax +39 0438 22428

Internet: www.kiwa.it - E-mail: info@kiwa.it

DECLARATION ON BEHALF OF IMMERGAS S.p.A.

Test performed on LPG/NG see note below	Original Boiler Name	UK Market Name	Full Load Efficiency (% net)	Part Load Efficiency (% net)
NG	HERCULES SOLAR 200 CONDENSING	HERCULES SOLAR 200 CONDENSING	96,9	107,9
NG	HERCULES SOLAR 200 CONDENSING*	HERCULES SOLAR 200 CONDENSING*	96,9	107,9
NG	HERCULES SOLAR 26 1 A	HERCULES SOLAR 26 1 A	96,9	107,9
NG	HERCULES SOLAR 26 1 A*	HERCULES SOLAR 26 1 A*	96,9	107,9

Boilers marked with an asterisk(*) are LPG models where the tests were carried out using Natural Gas (G20).

We declare that the full and part load efficiency test results detailed above have been obtained by means deemed to satisfy the Boiler Efficiency Directive (92/42/EEC). The water temperature criteria defined in the Boiler Efficiency Directive (see below) have been satisfied in obtaining these results.

Type of Boiler	Range of Power	Efficiency at rated output	Efficiency at part load
	KW	Average boiler-water temperature	Average boiler-water temperature
Standard boilers	4 to 400	70° C	≥ 50° C
Low temperature boilers ¹	4 to 400	70° C	40° C
Gas condensing boilers	4 to 400	70° C	30° C ²

¹ Including condensing boilers using liquid fuels.

² Temperature of boiler water supply.

San Vendemiano, 11/06/2009

Signed on behalf of **Kiwa Italia Spa.**

Kiwa Italia Spa.



Ronald Karel
Director Product Certification